



April 28, 2015

Re: DR14 CIOD PVC Spec-Loc Fittings
4"-16"

To whom it may concern:

Specified Fittings certifies compliance with the following standards and specifications for 4"-16" CIOD PVC Spec-Loc fittings it provides:

ASTM D1784, "Standard Specification for Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds."

ASTM D3139, "Standard Specification for Joints for Plastic Pressure Pipes Using Flexible Elastomeric Seals."

ASTM F477, "Standard Specification for Elastomeric Seals (Gaskets) for Joining Plastic Pipe."

All fittings shall be from NSF-61 materials for use in potable water systems.

Spec-Loc fittings are equipped with the Bulldog brand internal joint restraint system. These restraints are internal, integral and conform to the following:

ASTM F1674, "Standard Test Method for Joint Restraint Products for Use with PVC Pipe"

Some fitting configurations require external fiberglass reinforcement, as outlined under AWWA C900.

If you have any questions or need further information, please contact me.

Sincerely,

Brad Sukolsky
Specified Fittings