



# Specified Fittings, LLC

164 West Smith Road • PO Box 28157 • Bellingham, WA 98228-0157

7/25/19

To Whom it May Concern:

Specified Fittings certifies to the following specifications for non-pressure fittings for C900 and C905 PVC

pipe: FABRICATED FITTINGS FOR C905 PIPE

All fittings for 14" through 48" C905 pipe shall be one-piece injection molded or fabricated from a PVC compound meeting ASTM D1784. Solvent weld- or gasket-end fittings are option of user. Solvent weld bells shall be compatible with C905 pipe. Gasket bells shall conform to ASTM D3139 with gaskets conforming to F477. Gaskets shall be locked- in style. All fittings shall be from NSF-61 materials for use in potable water systems.

Fabricated FITTINGS FOR C900 pipe

All fittings for 4" through 12" C900 pipe shall be one-piece injection molded or fabricated from a PVC compound meeting ASTM D1784. Solvent weld- or gasket-end fittings are option of user. Solvent weld bells shall be compatible with C900 pipe. Gasket bells shall conform to ASTM D3139 with gaskets conforming to F477. Gaskets shall be locked- in style. All fittings shall be from NSF-61 materials for use in potable water systems.

If you have any other questions or need further information, please let us know.

Sincerely,

Brad Sukolsky

Technical and Quality Control Department Specified Fittings

