



November 18, 2019

Re: SDR 26 PVC Fittings for SDR Series Pipe

To Whom it May Concern:

Specified Fittings certifies SDR 26 PVC fittings provided for use with SDR Series PVC pipe to the following

FABRICATED SDR 26 IPS PVC FITTINGS

Fabricated fittings shall be made from SDR 26 PVC pipe made to ASTM D2241 or a combination of molded and fabricated subcomponents. PVC compound shall meet the requirements of cell class 12454 per ASTM D1784. Solvent weld bell or gasket-end fittings are option of user. Solvent weld bells shall be compatible with IPS pipe. Gasket bells shall conform to ASTM D3139 with gaskets conforming to F477. Gaskets shall be locked-in style. All fittings shall be from NSF-61 materials for use in potable water systems.

Thank you,

Brad Sukolsky
Specified